



Certificate of Compliance

Certificate: 1185170 (LL 53776-6)

Master Contract: 154019

Project: 2696698

Date Issued: February 28, 2014

Issued to: U.I. LAPP GmbH

Schulze-Delitzsch-Strasse 25
Stuttgart, 70565
Germany
Attention: Harry Pfeffer

The products listed below are eligible to bear the CSA Mark shown



Stanko Todoric

Issued by: Stanko Todoric

PRODUCTS

CLASS 5851 01 - WIRES - Appliance

Part A: Single conductor construction, AWM, I, A/B, rated 90°C, 300V and 600V, FT1, Oil ("O") Resistant, with PVC insulation, optional Nylon covering, optional shielding, optional PVC jacket.

Note: Jacketed construction may be marked as AWM, class I/II.

Part B: Multi-conductor, round cable construction, AWM I/II, A/B, rated 90°C, 300V and 600V, FT1, Optional Oil Resistant rating, with PVC insulation, optional Nylon covering, optional PVC inner covering, optional shielding, and PVC Jacket.

Part C: Multi-conductor, round cable construction, AWM, I/II, A, rated 80°C and 90°C, 600V, FT1, with PVC insulation, optional Nylon covering, optional PVC inner covering, optional shielding, and PVC Jacket.

Part D: Multi-conductor, round cable construction, AWM, I/II, A/B, rated 90°C, 300V and 600V, FT4, with PVC insulation, optional Nylon covering, optional PVC inner covering, optional shielding, and PVC Jacket.

Part E: Single conductor, round construction, AWM, I, A/B, rated 105°C, 300V, FT1, with PVC insulation.

Part F: Multi-conductor, round cable construction, AWM, I/II, A, rated 80°C, 300V, 600V, 1000V, FT1, with PP insulation, optional shielding, and PU jacket.

Part G: Multi-conductor, round cable construction, AWM, I/II, A, rated 80°C, 30V, FT1, with PP insulation, optional shielding, and PU jacket.



Certificate: 1185170 (LL 53776-6)

Master Contract: 154019

Project: 2696698

Date Issued: February 28, 2014

APPLICABLE REQUIREMENTS

CSA C22.2 No. 210 - Appliance Wiring Material Products