



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: **IECEX IBE 13.0026X** Page 1 of 4 Certificate history:  
Issue 0 (2013-10-23)

Status: **Current** Issue No: 1

Date of Issue: 2020-05-18

Applicant: **U. I. Lapp GmbH**  
Schulze-Delitzsch-Straße 25  
70565 Stuttgart  
Germany

Equipment: **Cable glands SKINTOP® MS-M\*\* ATEX \*\*\*, SKINTOP® MSR-M\*\* ATEX \*\*\*, SKINTOP® MS-M\*\* ATEX BRUSH \*\*\*, and SKINTOP® MSR-M\*\* ATEX BRUSH \*\*\*, as well as sealing plugs SKINTOP® SDV-M \*\*-ATEX \*\*\* and SKINTOP® SDVR-M\*\* ATEX \*\*\*,**

Optional accessory:

Type of Protection: **increased safety "e" and protection by enclosure "t"**

Marking: Ex eb IIC Gb  
Ex ta IIIC Da

Approved for issue on behalf of the IECEx  
Certification Body:

**Alexander Henker**

Position:

**Deputy Head of department Certification Body**

Signature:  
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting [www.iecex.com](http://www.iecex.com) or use of this QR Code.



Certificate issued by:

**IBEXU Institut für Sicherheitstechnik GmbH**  
Fuchsmühlenweg 7  
09599 Freiberg  
Germany





# IECEX Certificate of Conformity

Certificate No.: **IECEX IBE 13.0026X**

Page 2 of 4

Date of issue: 2020-05-18

Issue No: 1

Manufacturer: **U. I. Lapp GmbH**  
Schulze-Delitzsch-Straße 25  
70565 Stuttgart  
GERMANY  
**Germany**

Additional  
manufacturing  
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

#### STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

**IEC 60079-0:2017** Explosive atmospheres - Part 0: Equipment - General requirements  
Edition:7.0

**IEC 60079-31:2013** Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"  
Edition:2

**IEC 60079-7:2017** Explosive atmospheres - Part 7: Equipment protection by increased safety "e"  
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

#### TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

DE/IBE/EXTR13.0042/00

DE/IBE/ExTR13.0042/01

Quality Assessment Report:

DE/IBE/QAR13.0003/03



# IECEx Certificate of Conformity

Certificate No.: **IECEx IBE 13.0026X**

Page 3 of 4

Date of issue: 2020-05-18

Issue No: 1

## EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The Cable glands SKINTOP<sup>®</sup> MS-M\*\* ATEX \*\*\* and SKINTOP<sup>®</sup> MSR-M\*\* ATEX \*\*\* are suitable for dust tight and waterproof cable insertions in the mechanical and instrument engineering, instrumentation and control, chemical industry and plant construction, especially for fixed installed cables in potentially explosive atmospheres.

The Cable glands SKINTOP<sup>®</sup> MS-M\*\* ATEX \*\*\* and SKINTOP<sup>®</sup> MSR-M\*\* ATEX \*\*\* (with reduced seal insert) consist of distance piece and cover nut of brass, the PA insert with lamella cage of polyamide, the sealing ring for the lamella cage of CR/NBR as well as the o-ring for the connection side.

To close unneeded Cable glands type SKINTOP<sup>®</sup> MS-M\*\* ATEX \*\*\* respectively SKINTOP<sup>®</sup> MSR-M\*\* ATEX \*\*\* the respective Sealing plug SKINTOP<sup>®</sup> SDV-M\*\* ATEX \*\*\* respectively SKINTOP<sup>®</sup> SDVR-M\*\* ATEX \*\*\* can be used.

The Cable glands type SKINTOP<sup>®</sup> MS-M\*\* ATEX BRUSH \*\*\* and SKINTOP<sup>®</sup> MSR-M\*\* ATEX BRUSH \*\*\* use a ring brush as a low-resistance shield contact for optimal EMC protection.

Degree of Protection: IP66 / IP68 (10 bar / 30 min) according to IEC 60529

Operating temperature range: -30 °C up to +90 °C (Cable gland)

-30°C up to +70°C (Sealing plug)

For types and details see Annex

## SPECIFIC CONDITIONS OF USE: YES as shown below:

The cable glands SKINTOP<sup>®</sup> MS-M\*\* ATEX \*\*\* and SKINTOP<sup>®</sup> MSR-M\*\* ATEX \*\*\* may only be used for non-armoured and non-braided cables and only for fixed installations.

The Sealing plugs type SKINTOP<sup>®</sup> SDV-M\*\* ATEX \*\*\* respectively SKINTOP<sup>®</sup> SDVR-M\*\* ATEX \*\*\* may only be used in combination with the appropriate Cable gland SKINTOP<sup>®</sup> MS-M\*\* ATEX \*\*\* and SKINTOP<sup>®</sup> MSR-M\*\* ATEX \*\*\*.

The service temperature must not exceed 90 °C at the Cable gland and 70 °C at the Sealing plug.

The use of the cable shield of the cable glands SKINTOP<sup>®</sup> MS-M\*\* ATEX BRUSH \*\*\* and SKINTOP<sup>®</sup> MSR-M\*\* ATEX BRUSH \*\*\* in the function as the only earthed conductor or equipotential bonding conductor is not permitted.





# IECEX Certificate of Conformity

Certificate No.: **IECEX IBE 13.0026X**

Page 4 of 4

Date of issue: 2020-05-18

Issue No: 1

**DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)**

*The cable glands and sealing plugs will in be manufactured and marked in accordance with the standards IEC 60079-0 Ed. 7, IEC 60079-7 Ed. 5.1 and IEC 60079-31 Ed 2.*

*The cable gland SKINTOP® MS-M20 ATEX BRUSH \*\*\* is added.*

**Annex:**

[IBE13.0026X\\_1\\_Annex.pdf](#)



# IECEx Certificate of Conformity - Annex



Certificate No: IECEx IBE 13.0026X

Issue No: 1

Date of Issue: 2020-05-18

Page 1 of 1

Type designation	Thread size	Cable diameter (mm)	Torque (Nm)
SKINTOP® MS-M12 ATEX ***	M12 x 1,5	3-7	7
SKINTOP® MS-M16 ATEX ***	M16 x 1,5	4,5-10	7
SKINTOP® MS-M20 ATEX ***	M20 x 1,5	7-13	12
SKINTOP® MS-M20 ATEX BRUSH ***			
SKINTOP® MS-M25 ATEX ***	M25 x 1,5	9-17	12
SKINTOP® MS-M25 ATEX BRUSH ***			
SKINTOP® MS-M32 ATEX ***	M32 x 1,5	11-21	17
SKINTOP® MS-M32 ATEX BRUSH ***			
SKINTOP® MS-M40 ATEX ***	M40 x 1,5	19-28	17
SKINTOP® MS-M40 ATEX BRUSH ***			
SKINTOP® MS-M50 ATEX ***	M50 x 1,5	26-35	20
SKINTOP® MS-M50 ATEX BRUSH ***			
SKINTOP® MS-M63 ATEX ***	M63 x 1,5	34-45	20
SKINTOP® MS-M63 ATEX BRUSH ***			
SKINTOP® MS-M63 PLUS ATEX ***	M63 x 1,5	44-55	30
SKINTOP® MS-M63 PLUS ATEX BRUSH ***			

Type designation (design with reduced seal insert)	Thread size	Cable diameter (mm)	Torque (Nm)
SKINTOP® MSR-M12 ATEX ***	M12 x 1,5	2-5	7
SKINTOP® MSR-M16 ATEX ***	M16 x 1,5	4-7	7
SKINTOP® MSR-M20 ATEX ***	M20 x 1,5	5-10	12
SKINTOP® MSR-M25 ATEX ***	M25 x 1,5	6-13	12
SKINTOP® MSR-M25 ATEX BRUSH ***			
SKINTOP® MSR-M32 ATEX ***	M32 x 1,5	7-15	17
SKINTOP® MSR-M32 ATEX BRUSH ***			
SKINTOP® MSR-M40 ATEX ***	M40 x 1,5	16-23	17
SKINTOP® MSR-M40 ATEX BRUSH ***			
SKINTOP® MSR-M50 ATEX ***	M50 x 1,5	19-29	20
SKINTOP® MSR-M50 ATEX BRUSH ***			
SKINTOP® MSR-M63 ATEX ***	M63 x 1,5	32-39	20

\*\*\* = Manufacturer's indications without special meaning for the explosion protection  
(e. g. longer connection threads)

Operating temperature range: -30 °C bis +90°C  
Degree of protection  
according to EN 60529: IP66, IP68 (10 bar, 30 min)

#### Technical data Sealing plugs:

Type series SDV-M\*\* : M12, M16, M20, M25, M32, M40, M50 und M63  
Type series SDVR-M\*\* : M16, M20, M25 und M32  
Operating temperature range: -30 °C bis +70 °C  
Degree of protection  
according to EN 60529: IP66, IP68 (10 bar, 30 min)