



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312313000438

Page 1 of 2

Product information:

1. This certificate covers the following models:

- SKINDICHT® ME-M** ATEX ***, SKINDICHT® MR-M** ATEX ***

Detail type

MR-M 16/12 ATEX ***, MR-M 20/16 ATEX ***, MR-M 25/20 ATEX ***,

MR-M 32/25 ATEX ***, MR-M 40/32 ATEX ***, MR-M 50/40 ATEX ***,

MR-M 63/50 ATEX ***,

ME-M 12/16 ATEX ***, ME-M 16/20 ATEX ***,

ME-M 20/25 ATEX ***, ME-M 25/32 ATEX ***, ME-M 32/40 ATEX ***,

ME-M 40/50 ATEX ***, ME-M 50/63 ATEX ***

*** = Manufacturer's indications without special meaning for the explosion protection
(e. g. longer connection threads)

Thread size: M12×1.5, M16×1.5, M20×1.5, M25×1.5, M32×1.5, M40×1.5, M50×1.5,
M63×1.5

Rated service temperature range: -30°C~+90°C

Degree of protection: IP66, IP68 (10bar / 30min)

Ex marking: Ex e IIC Gb, Ex tD A20 IP66/68

- Producers should organize production in accordance with the technical documents
approved by the certification body.

2. Specific conditions of safety use:

- The service temperature must not exceed 90°C.

Issued on: 2021-11-08

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312313000438

Applicant	U.I. Lapp GmbH
Address	Schulze-Delitzsch-Straße 25, 70565 Stuttgart, Germany
Manufacturer	U.I. Lapp GmbH
Address	Schulze-Delitzsch-Straße 25, 70565 Stuttgart, Germany
Production Factory	U.I. Lapp GmbH
Production Address	Schulze-Delitzsch-Straße 25, 70565 Stuttgart, Germany
Product	Extensions and Reducers
Model/Type	SKINDICHT® ME-M** ATEX ***, SKINDICHT® MR-M** ATEX ***
Ex marking	Ex e IIC Gb, Ex tD A20 IP66/68
Reference Standards	GB3836.1-2010, GB3836.3-2010, GB12476.1-2013, GB12476.5-2013

Certification mode Type Test + Initial Factory Inspection + Post-Certification Surveillance

The product(s) is verified and certified according to CNCA-C23-01: 2019 *China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product* and CNEC-C2301-2019 *Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product*.

See Annex for the detailed product information (2 pages).

Issued on: 2021-11-08

Valid to: 2026-11-07

The validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the original Chinese version, the Chinese version shall prevail.

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China P.C.: 473008
Tel: 0377-63239734 Email: ccc@cn-ex.com

CN 0000855



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312313000438

Page 2 of 2

- See instruction for other information.
- 3. Certificate related report(s):
 - Type test report: CQST2105C031
 - Factory inspection report: CN2021Q010433
- 4. Certificate change information: None

Issued on: 2021-11-08

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.

