



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312313000439

<b>Applicant</b>	U.I. Lapp GmbH
<b>Address</b>	Schulze-Delitzsch-Straße 25, 70565 Stuttgart, Germany
<b>Manufacturer</b>	U.I. Lapp GmbH
<b>Address</b>	Schulze-Delitzsch-Straße 25, 70565 Stuttgart, Germany
<b>Production Factory</b>	U.I. Lapp GmbH
<b>Production Address</b>	Schulze-Delitzsch-Straße 25, 70565 Stuttgart, Germany
<b>Product</b>	Blanking plug
<b>Model/Type</b>	SKINDICHT® BL-M** ATEX ***
<b>Ex marking</b>	Ex e IIC Gb, Ex tD A20 IP66/68
<b>Reference Standards</b>	GB3836.1-2010, GB3836.3-2010, GB12476.1-2013, GB12476.5-2013

**Certification mode** Type Test + Initial Factory Inspection + Post-Certification Surveillance

The product(s) is verified and certified according to CNCA-C23-01: 2019 *China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product* and CNEC-C2301-2019 *Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product*.

See Annex for the detailed product information (2 pages).

Issued on: 2021-11-08

Valid to: 2026-11-07

The validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the original Chinese version, the Chinese version shall prevail.

Director:



Nanyang Explosion Protected Electrical  
Apparatus Research Institute Co., Ltd.



<http://www.ccc-cnex.com>  
[ccc.china-ex.com](http://ccc.china-ex.com)

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China  
Tel: 0377-63239734

P.C.: 473008  
Email: [ccc@cn-ex.com](mailto:ccc@cn-ex.com)

CN 0000856



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312313000439

Page 1 of 2

**Product information:**

1. This certificate covers the following models:

- SKINDICHT® BL-M\*\* ATEX \*\*\*

Type designation	Thread size
SKINDICHT® BL-M 12-ATEX ***	M12 × 1.5
SKINDICHT® BL-M 16-ATEX ***	M16 × 1.5
SKINDICHT® BL-M 20-ATEX ***	M20 × 1.5
SKINDICHT® BL-M 25-ATEX ***	M25 × 1.5
SKINDICHT® BL-M 32-ATEX ***	M32 × 1.5
SKINDICHT® BL-M 40-ATEX ***	M40 × 1.5
SKINDICHT® BL-M 50-ATEX ***	M50 × 1.5
SKINDICHT® BL-M 63-ATEX ***	M63 × 1.5

\*\*\* = Manufacturer's indications without special meaning for the explosion protection  
(e. g. longer connection threads)

Rated service temperature range: -30°C~+90°C

Degree of protection: IP66, IP68 (10bar/30min)

Ex marking: Ex e IIC Gb, Ex tD A20 IP66/68

- Producers should organize production in accordance with the technical documents approved by the certification body.

2. Specific conditions of safety use:

Issued on: 2021-11-08

Director:



Nanyang Explosion Protected Electrical  
Apparatus Research Institute Co.,Ltd.





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312313000439

Page 2 of 2

- The service temperature must not exceed 90°C.
  - See instruction for other information.
3. Certificate related report(s):
- Type test report: CQST2105C032
  - Factory inspection report: CN2021Q010433
4. Certificate change information: None

Issued on: 2021-11-08

Director:



Nanyang Explosion Protected Electrical  
Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>  
[ccc.china-ex.com](http://ccc.china-ex.com)

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China P.C.: 473008  
Tel: 0377-63239734 Email: [ccc@cn-ex.com](mailto:ccc@cn-ex.com)